



**2022 Sports Court Fence Replacement  
C-2022-0010  
Addendum 1  
November 22, 2021**

Note: This Addendum shall be included as part of the Bid Form Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form and on the Bid Tabulation. Failure to do so may subject the Bidder to Disqualification.

RESPONSE TO BIDDERS QUESTIONS/CLARIFICATIONS/CORRECTIONS:

1. ITEM #39 in the Bid Document (**Scope at each set of Tennis Courts**) should read:  
New chain link shall be 8-gauge finish black vinyl coated **1 ¾"** diamond pattern, KK **instead of 2"** diamond pattern.  
  
ITEM 40 in the Bid Document (**Scope at the Skate Park**) **remains unchanged** with the new chain link at the specified 8-gauge finish black vinyl coated **2"** diamond pattern, KK.
2. The correct address for Terramont Park where the tennis court fence is to be replaced is:  
Terramont Park, 8500 Terramont Drive, The Woodlands, TX 77382

**This Addendum must be *Signed & Returned* with your bid.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company

\_\_\_\_\_  
Name (please print)

\_\_\_\_\_  
Phone

\_\_\_\_\_  
Date

\_\_\_\_\_  
Email